#### DOCKET NO. D-1969-066 CP-5

#### **DELAWARE RIVER BASIN COMMISSION**

Bucks County Sewer and Water Authority Wastewater Treatment Plant Bristol Township, Bucks County, Pennsylvania

#### **PROCEEDINGS**

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on August 31, 2023 (Application), for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The Pennsylvania Department of Environmental Protection (PADEP) issued National Pollutant Discharge Elimination System (NPDES) Permit No. PA0027294 for this discharge.

The Application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Bucks County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on November 6, 2024.

# A. DESCRIPTION

- **1. Purpose**. The purpose of this docket is to renew approval of the docket holder's existing 2.7 million gallons per day (mgd) WWTP and its discharge.
- **Location**. The docket holder's WWTP is located at Maple Beach Road in Bristol Township, Bucks County, Pennsylvania. The WWTP will continue to discharge treated effluent to Otter Creek, which is a tidal tributary to Delaware River Water Quality Zone 2 at River Mile 118.9 0.3 (Delaware River Otter Creek).

The location of the WWTP outfall in the Delaware River Watershed is as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	40° 05' 39"	74° 51' 47"

**Area Served.** The docket holder's WWTP will continue to serve Bristol Borough and a portion of Bristol Township both located in Bucks County, Pennsylvania. For the purpose of defining the Area Served, the Type of Discharge and the Service Area sections from the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in Section C. DECISION of this docket.

- **4.** <u>Design Criteria</u>. The docket holder's 2.7 mgd WWTP utilizes a trickling filter / rotating biological contractor (RBC) treatment process.
- **5.** <u>Facilities</u>. The WWTP facilities consist of grit removal, two (2) primary clarifiers, four (4) first stage trickling filters, six (6) rotating biological contactors, two (2) secondary clarifiers, and a chlorine contact system. Sludge handling is provided by two (2) anaerobic sludge digestors.

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site for disposal in accordance with the NPDES Permit No. PA0027294.

- **Mater Withdrawals**. The potable water supply in the project service area is provided by a surface water withdrawal owned and operated by Aqua Pennsylvania, Inc., which is described in detail in Docket No. D-1978-083 CP-2, approved on September 10, 2014.
- 7. NPDES Permit / DRBC Effluent Requirements. NPDES Permit No. PA0027294 issued by the PADEP includes final effluent limitations for the project discharge to surface waters classified by the PADEP as supporting warm water fishes and migratory fishes (WWF/MF) EFFLUENT TABLE C-1 included in Section C. DECISION condition C.1. of this docket, contains effluent requirements for DRBC parameters that must be met as a condition of this approval. Effluent requirements for Outfall No. 001 are based on a discharge rate of 2.7 mgd.
- **Relationship to the Comprehensive Plan**. The existing WWTP was included in the Comprehensive Plan by Resolution No. R-62-14. Expansion of the WWTP was incorporated into the Comprehensive Plan via Docket Nos. D-1969-066 CP-1 and D-1969-066 CP (Revised), which were approved by the Commission on June 22, 1971 and September 30, 1976, respectively. The WWTP was renewed via Docket Nos. D-1969-066 CP-3 and D-1969-066 CP-4 on May 8, 2013 and March 13, 2019, respectively. Issuance of this docket will continue the WWTP and its discharge in the Comprehensive Plan.

### **B. FINDINGS**

The docket holder applied to renew approval of their existing 2.7 mgd WWTP and its discharge.

## 1. CBOD<sub>20</sub> Wasteload Allocation & Monitoring

The Commission's Water Quality Regulations (*WQR*) provide for the allocation of the stream assimilative capacity where waste discharges would otherwise result in exceeding such capacity. The DRBC determined in the late 1960's that discharges to the Delaware Estuary would be limited to a total of 322,000 lbs/day of carbonaceous biochemical (first stage) oxygen demand (later noted as CBOD<sub>20</sub>). In accordance with the *WQR*, the assimilative capacity of each Delaware Estuary zone minus a reserve was originally allocated in 1968 among the individual dischargers based upon the concept of uniform reduction of raw waste in a zone (Zones 2, 3, 4 and 5). The totals and percent reduction for each zone are given in Table 1 of the Commission's *Status of CBOD*<sub>20</sub> *Wasteload Allocations* (Revised October 1, 2000). The docket holder's WWTP is located in Zone 2 at River Mile 118.9. Zone 2 is allocated at 18,600 lbs/day of CBOD and has a total reduction requirement of 88.5%. Compliance with the 88.5% Zone 2 reduction requirement can be demonstrated by meeting the 88.5% CBOD<sub>5</sub> removal requirement included in EFFLUENT TABLE C-1 in Section C. DECISION condition C.1. of this docket.

The Commission approved a  $CBOD_{20}$  allocation for the WWTP of 640 lbs/day in Docket No. D-1969-066 CP-1 (Revised), approved on June 22, 1971. The  $CBOD_5$  effluent load limit is calculated as the  $CBOD_{20}$  allocation divided by the  $CBOD_{20}/CBOD_5$  ratio of 1.75:1. This docket continues the allocation of up to 640 lbs/day of  $CBOD_{20}$  for the existing facility. Compliance with the  $CBOD_{20}$  allocation can be demonstrated by meeting the  $CBOD_5$  effluent load limit of 366 lbs/day.

### 2. Other

At the docket holder's discharge location, Otter Creek is tidal.

The nearest surface water intakes of record for public water supply are located on the Delaware River (City of Philadelphia Water Department), approximately 9 River Miles downstream and 1 mile upstream (Aqua Pennsylvania).

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit conform with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge that meets the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

# C. <u>DECISION</u>

Effective on the approval date for Docket No. D-1969-066 CP-5 below, the project described in Docket No. D-1969-066 CP-4 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-1969-066 CP-5; Docket No. D-1969-066 CP-4 is terminated and replaced by Docket No. D-1969-066 CP-5; and the project and the appurtenant facilities described in Section A "DESCRIPTION" of this docket shall be included in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

# **Monitoring and Reporting**

The docket holder shall comply with the requirements contained in the EFFLUENT 1. TABLES below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.gov on the Annual Effluent **Monitoring** Report Form located at this web address: https://www.nj.gov/drbc/programs/project/docket-app-info.html#3. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit

OUTFALL 001 (Otter Creek)				
PARAMETER	LIMIT	MONITORING		
pH (Standard Units)	6 to 9 at all times	As required by NPDES permit		
Total Suspended Solids	30 mg/l	As required by NPDES permit		
CBOD (5-Day at 20° C)	17 mg/l (88.5% Minimum Removal) 366 lbs/day	As required by NPDES permit		
Ammonia-Nitrogen	35 mg/l	As required by NPDES permit		
Fecal Coliform	200 colonies per 100 ml as a geo. Avg	As required by NPDES permit		
Chronic WET Ceriodaphnia Survival	Monitor & Report	As required by NPDES permit		
Chronic WET Ceriodaphnia Reproduction	Monitor & Report	As required by NPDES permit		
Chronic WET Pimephales Survival	Monitor & Report	As required by NPDES permit		

OUTFALL 001 (Otter Creek)				
PARAMETER	LIMIT	MONITORING		
Chronic WET Pimephales Growth	Monitor & Report	As required by NPDES permit		
PCBs	Monitor & Report	As required by NPDES permit		
Total Dissolved Solids*	1,000 mg/l *	One Per Quarter *		

<sup>\*</sup> See DECISION Condition C.4.

- 2. The discharge of wastewater shall not increase the ambient temperatures of the receiving waters by more than 5°F above the average 24-hour temperature gradient displayed during the 1961-1966 period, nor shall such discharge result in stream temperatures exceeding 86°F.
- **3.** Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.
- 4. The docket holder may request permission from the Executive Director to perform specific conductance monitoring in lieu of TDS monitoring. The request shall be made in writing and shall include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow specific conductance monitoring in lieu of TDS monitoring.
- 5. This approval shall expire on the expiration date set forth below unless prior thereto the docket holder has applied to the Commission to renew or extend this approval.
- 6. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the grant or denial of the application for docket approval.
- 7. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference the Type of Discharge and Service Area sections of the docket holder's Application to the extent consistent with all other conditions of this section. Any expansion beyond that included in Section A.3. Area Served is subject to DRBC review and approval in accordance with Section 3.8 of the Compact.

- 8. In accordance with the Commission's regulations at 18 C.F.R. Part 440, the docket holder is prohibited from discharging wastewater from high volume hydraulic fracturing ("HVHF") or HVHF-related activities to waters or land within the Basin. The docket holder is further prohibited from discharging hydraulic fracturing wastewater, whether treated or untreated, from sources within or outside the Basin, without obtaining the Commission's prior review and express approval in the form of a revised docket. Violation of this or any condition of this docket approval may result in enforcement, including the risk of financial penalties, pursuant to Section 14.17 of the Delaware River Basin Compact and Section 2.7.8 (18 CFR 401.98) of the Commission's Rules of Practice and Procedure.
- **9.** The facility and operational records shall be available at all times for inspection by the DRBC.
- 10. The facility shall be operated at all times to comply with the requirements of the Commission's WQR.
- 11. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.
- 12. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.
- 13. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
- 14. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
- 15. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, to ensure proper control, use and management of the water resources of the Basin.
- **16.** The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 C.F.R. 401.43).
- 17. This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).

- 18. The docket holder shall request a name change of the entity to which this approval is issued if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
- 19. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
- **20.** Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure (RPP)*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

#### BY THE COMMISSION

APPROVAL DATE: December 5, 2024

**EXPIRATION DATE:** August 31, 2029