

JURISDICTIONAL NOTIFICATION OF A PRODUCT RECALL THAT COULD POSE AN IMMEDIATE HAZARD IF NOT CORRECTED

Note: This notice was sent on April 21, 2014 to Contractors who install Weil-McLain boilers.

This is an important safety recall that was mailed out to all Contractors who install Weil-McLain Boilers. All Inspectors, Contractors, and Owners should be aware of the specific models affected. Please be diligent in your inspection of these Ultra Gas Boilers and the flaw that could cause a gas leak and pose an imminent hazard.



**TO: All Weil-McLain Ultra Series Boiler Installers
Ultra™ Series Boiler Safety Recall – Contractor Notice**

Below is a copy of a [letter](#) that was mailed on April 21st via USPS to Contractors who install Weil-McLain boilers.

IMPORTANT SAFETY RECALL NOTICE FOR ULTRA GAS BOILER INSTALLERS

Date: April 21, 2014

Subject: Weil-McLain® Ultra™ Series Boilers - Ultra 80, Ultra 105, Ultra 155 and Ultra 230

Dear Weil-McLain Ultra Series Boiler Installer:

Weil-McLain has received information indicating that a cap on the boiler manifold tube for Weil-McLain Ultra 80, Ultra 105, Ultra 155, and Ultra 230 MBH condensing, high-efficiency, gas-fired boilers manufactured **after June 1, 2012 and prior to March 11, 2014**, can crack and allow gas to leak. If this happens, a risk of fire or explosion may arise. The CP Number range of affected boilers is **CP 6557046** through **CP 6955985**. An illustration showing the locations of the boiler model and CP number labels is enclosed. Weil-McLain is aware of multiple instances of cracked caps, but only one incident of gas leakage and no fires have occurred.

If you purchased and installed one of these boilers, please contact Weil-McLain at **888-770-7139** immediately to obtain a replacement manifold.

Also enclosed with this notification are:

- [Instructions](#) for checking the gas manifold cap and, if necessary, repair steps
- [Documentation and Reimbursement Initiation Form](#)

NOTE: NO REIMBURSEMENT WILL BE MADE ON FORMS RECEIVED WITHOUT A CP NUMBER.

Compensation will only be provided for Ultra Series boilers with CP numbers **CP 6557046**

through **CP 6955985**. Consumers may call Weil-McLain at **888-770-7139** or visit our [website](#) or the U.S. Consumer Product Safety Commission's website www.cpsc.gov.

Where do I find the boiler Serial Number (CP Number)?

Answer: Remove the front jacket by removing the two black thumb screws at the bottom. CP label is inside the boiler. See pictures below.



Two Thumb Screws



CP Number

www.weil-mclain.com

999 McClintock Drive Suite 200 | Burr Ridge, IL 60527 US

This email was sent to bam132@psu.edu. To ensure that you continue receiving our emails, please add us to your address book or safe list.

[manage](#) your preferences | [opt out](#) using TrueRemove®.

Got this as a forward? [Sign up](#) to receive our future emails.

