

**STATE OF NEW JERSEY  
OFFICE OF ADMINISTRATIVE LAW  
BEFORE THE HONORABLE WALTER J. BRASWELL**

I/M/O THE PETITION OF )  
PUBLIC SERVICE ELECTRIC AND )  
GAS COMPANY FOR APPROVAL OF )  
AN INCREASE IN ELECTRIC AND )  
GAS RATES AND FOR CHANGES IN )  
THE TARIFFS FOR ELECTRIC AND )  
GAS SERVICE, ) BPU DOCKET No. GR09050422  
B.P.U. N.J. NO. 14 ELECTRIC AND ) OAL DOCKET No. PUC-7559-09  
B.P.U. N.J. NO. 14 GAS PURSUANT TO )  
N.J.S.A. 48: 2-21 AND N.J.S.A. 48: 2-21.1 )  
AND FOR APPROVAL OF GAS )  
WEATHER NORMALIZATION; )  
A PENSION EXPENSE TRACKER AND )  
FOR OTHER APPROPRIATE RELIEF )

---

**DIRECT TESTIMONY OF CHARLES P. SALAMONE  
ON BEHALF OF THE  
NEW JERSEY DEPARTMENT OF THE PUBLIC ADVOCATE  
DIVISION OF RATE COUNSEL**

---

**RONALD K. CHEN  
PUBLIC ADVOCATE OF NEW JERSEY**

**STEFANIE A. BRAND, ESQ.  
DIRECTOR, DIVISION OF RATE COUNSEL**

**DIVISION OF RATE COUNSEL  
31 Clinton Street, 11<sup>th</sup> Floor  
P. O. Box 46005  
Newark, New Jersey 07101  
Phone: 973-648-2690  
Email: njratepayer@rpa.state.nj.us**

**FILED: November 19, 2009**

**REDACTED VERSION**

## TABLE OF CONTENTS

	<b>Page No.</b>
I. STATEMENT OF QUALIFICATIONS .....	1
II. PURPOSE OF TESTIMONY .....	2
III. RELIABILITY.....	3
IV. PSE&G'S PROJECT EVALUATION SYSTEM.....	6
V. CAPITAL INFRASTRUCTURE PROGRAM .....	10
VI SUMMARY .....	14

1   **I. STATEMENT OF QUALIFICATIONS**

2   **Q. Please state your name and business address.**

3   A. My name is Charles P. Salamone. I am Owner of Cape Power Systems  
4   Consulting, LLC a power systems consulting Company with an address of 23  
5   Westerly Drive, Bourne, Massachusetts and I am subcontracting with Synapse  
6   Energy Economics, Inc. with an address of 22 Pearl Street, Cambridge,  
7   Massachusetts.

8   **Q. On whose behalf are you submitting testimony in this proceeding?**

9   A. I am submitting testimony on behalf of the New Jersey Department of the Public  
10   Advocate, Division of Rate Counsel.

11   **Q. Please describe your education and professional background.**

12   A. I hold a Bachelor of Science Degree in Electrical Engineering from Gannon  
13   University. I joined the Engineering Department of Commonwealth Electric  
14   Company in 1973. At that time, I became a Junior Planning Engineer where my  
15   primary responsibilities were to assist in the planning, analysis and design of the  
16   transmission and distribution systems of Commonwealth Electric Company. I  
17   generally followed the normal progression of positions with increasing levels of  
18   responsibility within the planning area until taking the position of Director of  
19   System Planning in 2000. I retired from NSTAR (the successor entity formerly  
20   Commonwealth Electric and Boston Edison) in 2005 and formed my own  
21   consulting Company. During my career with NSTAR in addition to the  
22   responsibilities associated with overseeing System Planning I had served as Chair

1 of the NEPOOL Planning Policy Subcommittee (1997-1998), Chair of the  
2 NEPOOL Regional Transmission Planning Committee (1998-1999) and Vice  
3 Chair of the NEPOOL Reliability Committee (1999-2000). As a consultant I  
4 have been providing consulting services to a number of power system industry  
5 clients since 2005. I am a Registered Professional Engineer with the  
6 Commonwealth of Massachusetts. I am also a member of the Power Engineering  
7 Society of the Institute of Electrical and Electronic Engineers. A copy of my  
8 resume is attached hereto as Attachment CPS-A.

9 **Q. Have you previously testified before utility regulatory agencies?**

10 A. Yes. I have previously testified before the Federal Energy Regulatory  
11 Commission, the Massachusetts Department of Telecommunications and Energy  
12 and the Massachusetts Energy Facilities Siting Board on a number of technical  
13 matters relating to ratemaking and system planning.

14 **II. PURPOSE OF TESTIMONY**

15 **Q. What is the purpose of your testimony in this proceeding?**

16 A. The purpose of my testimony is to discuss Public Service Electric and Gas  
17 Company (“PSE&G” or the “Company”) practices concerning maintaining  
18 reliability of service for customers served by its electric distribution system. This  
19 includes consideration of the expenditures PSE&G has incurred in support of  
20 reliability versus the benefits achieved from such expenditures. I will discuss the  
21 prioritization process used by PSE&G and the issues this process raises  
22 concerning maintaining a minimum level of reliability. The reliability statistics

1       when taken on a PSE&G wide basis are above average in nature however, the  
2       performance of individual circuits tells a very different story. PSE&G's heavy  
3       reliance on divisional reliability statistics has allowed segments of the system to  
4       fall short of acceptable performance. I will discuss the concerns that arose with  
5       respect to PSE&G's planning practices and the impacts this has on service to  
6       customers. A review of the process used by PSE&G for selection of projects  
7       found that it focuses on global characteristics at the expense of local reliability.  
8       An additional concern is the recent low voltage network failures that are also  
9       indicative of insufficient recognition of the impacts of network failures on  
10      customer service. Finally, I will discuss the projects submitted under the  
11      Economic Stimulus Program, PSE&G's Capital Infrastructure Investment  
12      Program ("CIIP") with respect to the appropriateness of their inclusion for rate  
13      recovery at this time.<sup>1</sup>

14      **III. RELIABILITY**

15      **Q. What reliability problems did you observe in the review of data provided by**  
16      **PSE&G?**

17      A. My assessment found that some customers are left with highly unacceptable  
18      performance, which apparently does not impact the statistics at a high level. A  
19      review of the individual circuit performance for 2006, 2007 and 2008 based on  
20      response to inquiry RCR-ER-2 indicates that there were 324, 321 and 297 circuits  
21      respectively with a CAIDI value that was worse than the mean value of

---

<sup>1</sup> See I/M/O the Petition of Public Service Electric and Gas Company For Approval of A Capital Economic Stimulus Infrastructure Investment Program and An Associated Cost Recovery Mechanism Pursuant to

1 performance for the benchmark group PSE&G has established for itself. (See  
2 Attachment CPS-B) Similarly the individual circuit performance for 2006, 2007  
3 and 2008 indicates that there were 303, 329 and 314 circuits respectively with a  
4 SAIFI value worse than the mean value of the benchmark group. (See Attachment  
5 CPS-C) Many of these circuits also show up year over year. The results indicate  
6 that while PSE&G is able to maintain reasonable Divisional performance statistics  
7 there are a number of customers that are experiencing reliability performance well  
8 below acceptable levels.

9

10 **Q. Are there other planning related concerns observed in your review?**

11 A. PSE&G's Distribution Planning Process was also found to lend itself to exposing  
12 individual circuits to reliability risks. The process of weather normalization used  
13 by PSE&G in establishing forecasted peak demands can easily expose circuits and  
14 substations to demands that are from 20% to 40% higher than expected based on  
15 response to inquiry, i.e. RCR-ER-16. This process assumes "normal" weather  
16 conditions as the basis for developing a load forecast. Such forecasts ignore the  
17 impacts of weather that is not "normal" which can have a significant effect on  
18 actual distribution system loading. The load characteristics of today's customers  
19 are much more sensitive to weather conditions than in the past resulting in greater  
20 variability in electric power demands. The introduction of air conditioners that  
21 cost less than \$100 has resulted in significantly higher loads occurring when

1       temperatures are above 98 degrees especially if this occurs on three or more  
2       consecutive days. Conditions similar to this occurred in 2006 and the peak  
3       demands recorded by PSE&G are consistent with this type of weather condition.  
4       Those demands were in many cases the highest values seen in the past three years.  
5       PSE&G's current projected weather normalized loading for circuits is often less  
6       than these prior peak demands and a repeat of the 2006 weather conditions could  
7       easily drive demands to substantially higher levels than the system is designed to  
8       operate at based on weather normalization. PSE&G's distribution system cannot  
9       be operated in a reliable fashion if its design is based on a weather normalization  
10      process that excludes such demands from consideration in planning and designing  
11      the system. Based on data included in response to inquiry RCR-ER-12 there are  
12      62 circuits that are projected to have normalized peak demand loading that  
13      exceeds the circuit's capacity by more than 10%. Additionally, there are a  
14      significant number of these circuits that are projected to have overloads in excess  
15      of 25% beyond their capacity over the next three years based on their normalized  
16      load projection values (See Attachment CPS-D). These numbers suggest that  
17      PSE&G's planning process allows for a significant level of risk of overload for  
18      individual circuits. The consequence is that a large number of customers face the  
19      potential for being interrupted over a significant number of hours during the year  
20      .loads are typically over 75% of peak 500 hours or more per year). When  
21      considered in the context of the past performance of individual circuits it appears  
22      that mitigation of circuit reliability issues related to insufficient capacity are a low  
23      priority for PSE&G funding.

1

2 Q. How has PSE&G cost effectively addressed circuit reliability?

3 A. Some of PSE&G's approaches such as the practice of maintaining an energized  
4 stand-by circuit that does not perform any useful function except when another  
5 circuit has failed are not commonly used in the industry. In my opinion this is not  
6 a cost effective means for providing backup service. A more typical practice is to  
7 reserve some percentage of capacity on active and functioning circuits to allow  
8 for transfer of loads from adjacent circuits during a circuit failure. The stand-by  
9 circuit practice raises concerns over the appropriateness of inclusion of such  
10 circuits in rate base. Except for the fact that the circuits are energized they are  
11 somewhat similar to spare transformers sitting in PSE&G's stock room waiting to  
12 be put in service in response to a transformer failure. Greater investments in  
13 active circuit capacity as well as load management and energy efficiency  
14 programs would be a more cost effective means to provide back-up capacity for  
15 the system.

#### 16 IV. PSE&G'S PROJECT EVALUATION SYSTEM

17 Q. [Confidential testimony begins here]  
18

19 A

20

21

22

23

Testimony of Charles P. Salamone  
On Behalf of  
Division of Rate Counsel  
Page 7

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

Testimony of Charles P. Salamone  
On Behalf of  
Division of Rate Counsel  
Page 8

1

2

3

4

5       **Q.**

6

7       A.

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

Testimony of Charles P. Salamone  
On Behalf of  
Division of Rate Counsel  
Page 9

1  
2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23       *Confidential testimony ends here]*

1

2   **V. CAPITAL INFRASTRUCTURE PROGRAM**

3   **Q. Did you review the Capital Infrastructure Investment Program projects**  
4   **submitted by PSE&G?**

5   A. Yes. PSE&G has submitted and obtained approval to proceed with a number of  
6        projects that PSE&G maintains are incremental to the work that it had funded for  
7        the 2009 through 2011 budget years. The set of projects submitted by PSE&G  
8        raises a number of concerns from both a reliability perspective and an economic  
9        perspective.

10   **Q. Could you explain the concerns that arise from the set of reliability projects**  
11   **submitted for the Capital Infrastructure Investment Program?**

12   A. The projects submitted by PSE&G indicate a number of significant reliability  
13        concerns across the system that, absent the stimulus funding, would have been  
14        deferred. This deferral was not the result of any expectation of a decrease in  
15        system demand but simply due to a cut in spending for such projects. The  
16        PSE&G's load projections for 2008 shown in Table 1 below demonstrate that  
17        PSE&G's projection of peak demands were actually expected to be higher than  
18        what was previously projected. This should have resulted in additional projects  
19        being identified and additional projects funded by PSE&G to address the higher  
20        capacity demands being placed on the system. The response of PSE&G to this  
21        information was inconsistent and rather than adding projects it elected to remove  
22        projects due to budget constraints. As explained earlier, the IES system used by  
23        PSE&G favors larger scale projects over local projects and it allows for

Testimony of Charles P. Salamone  
On Behalf of  
Division of Rate Counsel  
Page 11


1 establishing a funding level that defers projects without consideration of any  
2 reliability thresholds. As a consequence, the projects submitted for stimulus  
3 funding were removed from the current year's budget. PSE&G's response to  
4 question RC-PS-IN-P-30 in the economic stimulus proceeding describes the  
5 reliability projects included for funding under the Capital Infrastructure  
6 Investment Program. These projects included some that were solutions to  
7 projected overloads of up to 68% based on weather normalized projections for  
8 2010. These projects had been cut from PSE&G's project list based on a budget  
9 reduction of \$76M in electric distribution funding as indicated in response to  
10 question RC-PS-IN-A-30. The list of projects that were considered as not  
11 important enough to fund demonstrates the concern with a system that does not  
12 establish a minimum level of reliability of service to customers. Customers that  
13 are served by a circuit that is projected to experience a 68% overload will most  
14 certainly experience outages due to overloads and a failure to recognize this is a  
15 significant flaw in the evaluation system that PSE&G uses. The only stimulus  
16 projects that should be considered in PSE&G's base rate case are projects that  
17 would normally be included in the test year. All other projects should be included  
18 in future CIIP reviews.

19

20

21

22




**TABLE 1**

Q. **Were there any other projects submitted for rate recovery at this time that were part of the Capital Infrastructure Investment Program?**

A. Yes. There are a number of projects that were included in PSE&G's rate case filing that were approved as part of the Capital Infrastructure Investment Program. Based on PSE&G's most recent quarterly filing as required under the CIIP stipulation, filed on November 4, 2009, there are 38 electric division CIIP projects that PSE&G is seeking recovery for. The total estimated cost for these projects is \$421,313,557. Over 50% of these projects are not due to be completed until 2011 and they encompass over 70% of the capital expenditures of the CIIP. As can be seen in Table 2 below there are only two CIIP electric projects that are more than

1       50% complete and a majority of projects have less than 20% of the projected  
2       work completed. Additionally, there are only 11 CIIP electric projects that have  
3       completed some percentage of work. Based on the data provided in the quarterly  
4       filings for these projects, on average the CIIP project costs are projected to be  
5       60% greater than their original estimated cost. Given the limited number of CIIP  
6       projects completed and the implied variation in completed project costs it would  
7       not appear to be prudent to provide unconstrained approval for inclusion of these  
8       project costs within PSE&G's rate increase. A review of the costs and prudence  
9       of these projects should be done in the future economic stimulus CIIP reviews,  
10      before they are included for cost recovery in customer rates.



11  
12

**TABLE 2**

1   **VI      SUMMARY**

2   **Q. Please summarize your conclusions and recommendations regarding the**  
3   **ratemaking issues concerning PSE&G's rate case filing?**

4   A. First, I found that PSE&G's prioritization process should be reviewed and  
5   adjusted to allow for greater concentration on reliability based projects that are  
6   area specific in nature. I would recommend that this process be adjusted to treat  
7   large scale projects separately from local area reliability and capacity problem  
8   related projects. Large scale project should be funded through development of  
9   complete business plans and should compete among similar projects rather than  
10   divert funding from local area reliability projects. Additionally, the reliability  
11   performance metrics used by PSE&G's project funding process should be  
12   adjusted to allow for greater recognition of area specific problems with more  
13   emphasis on risks and reliability performance of local area reliability. In general,  
14   PSE&G should place less emphasis on large scale high technology projects and  
15   more on the low technology distribution system element projects. Second, greater  
16   investments in active circuit capacity as well as load management and energy  
17   efficiency programs rather than programs such as stand-by circuits should be  
18   implemented as a more cost effective means to provide back-up capacity for the  
19   system. Third, network reliability evaluations should be measured on a different  
20   basis than traditional CAIDI and SAIFI performance metrics and should consider  
21   the actual number of people and businesses impacted by network outages. I would  
22   recommend treating any PSE&G low voltage network outage that impacts more  
23   than 50 occupants should be treated as more than one customer for statistical

1 reporting purposes and for prioritization of projects. Fourth, I recommend that  
2 planning practices set a higher priority on identifying and mitigating system  
3 overloads and consider basing load forecast projections on more severe weather  
4 conditions than those incorporated in weather normalized forecast for use in the  
5 planning process. Finally, the future cost and completion dates for stimulus  
6 program projects appear to have a high degree of uncertainty based on the  
7 information PSE&G has provided. On this basis, projects included in the Capital  
8 Infrastructure Investment Program should be subject to a future review that  
9 considers the prudence of the completed project costs once the projects are  
10 completed, prior to consideration of their inclusion in rate base. .

11 Q. **Does this conclude your testimony?**

12 A. Yes. However, I reserve the right to supplement my testimony based on further  
13 updates to discovery and PSE&G's rebuttal testimony.

**EXHIBIT ATTACHMENT CPS-A**



Cape Power Systems Consulting, LLC

# Charles P. Salamone PE

## Attachment CPS-A

### Charles P. Salamone, P.E.

**Profession:** Power Systems, with a special emphasis on transmission planning and design

**Nationality:** U.S. Citizen

#### Years of

**Experience:** 34 years

**Education** B.S.E.E, Power System Engineering, 1973  
Gannon University, Erie, PA

**Position:** Owner/Manager, Cape Power Systems Consulting

**Web/Email:** [www.CapePowerSystems.com](http://www.CapePowerSystems.com) csalamone@capepowersystems.com

**Summary:** Mr. Salamone provides professional services based on his 34 years of experience in the areas of Transmission Planning, Substation Planning, Distribution Planning ISO-New England Procedures, New England Power Pool Procedures, Congestion Management, Generator Interconnections, Meter Engineering, Planning Budget Management, and State (Mass DTE) and Federal (FERC) Regulatory Agency Filing Development and Expert Witness Testimony

Experience:

**2005- Pres.** **Cape Power Systems Consulting**

Established a power system design, analysis, planning and assessment consulting company to work directly with diverse power system stakeholders.

- Work with a number of clients concerning development of analysis, reports and presentations in support of regulatory and technical review/approval process for transmission and distribution projects.
- Provide technical assistance for transmission planning activities for an Independent System Operator including support for major transmission system expansion programs and development of a 10 year transmission plan



Cape Power Systems Consulting, LLC

## Charles P. Salamone PE

- Developed and conducted a comprehensive training program for implementation of EMS based transmission system security assessment procedures for a large Massachusetts utility
- Work with Massachusetts Technology Collaborative providing technical support concerning electric utility design and analysis activities

**1979-2005      NSTAR (Previously Boston Edison and Commonwealth Electric)**

**2000-2005      Director System Planning**

NSTAR (Previously Boston Edison and Commonwealth Electric) Boston, MA

- Responsible for long term planning of Company transmission, substation and distribution systems
- Successfully managed the studies, design, internal and external review and regulatory approval for a \$250M 345 kV underground transmission expansion project serving the greater Boston area
- Responsible for managing generator interconnection studies, design and approvals
- Successfully managed studies, design and approval for congestion mitigation plans and expansion project
- Oversaw transmission and distribution planning efforts to establish a comprehensive 10 year \$300 million system expansion plan
- Served as Company representative on NEPOOL Reliability Committee and the New England Transmission Expansion Advisory Committee
- Served as Company expert witness for system planning related regulatory proceedings at both the state and federal levels.
- Supervised a staff of 10 senior engineers

**1989-1999      Manager, System Planning and Meter Services**

Commonwealth Electric Company, Wareham, MA

- Develop risk based prioritized \$10 million construction budget procedures
- Supervise a staff of 6 professional engineers and 4 analysts
- Served as chair of the NEPOOL Regional Transmission Planning Committee (currently the NEPOOL Reliability Committee)
- Process billing determinant and interval data for all major system customers
- Lead implementation of first MV90 meter data processing system
- Develop annual performance analysis reports for all transmission and major distribution systems
- Manage multiple FERC tariff based transmission customer and generation developer system impact studies
- Served as expert Company witness in State and FERC regulatory proceedings
- Initiated implementation of a risk index for prioritization of all transmission and major distribution construction projects



Cape Power Systems Consulting, LLC

# Charles P. Salamone PE

- Initiated implementation of automated electronic processing of major customer billing data, which significantly reduced time needed to generate bills
- Served as lead member on information technology company merger team
- Implemented process and equipment to perform all tie line, generator and wholesale customer meter testing
- Served as chair of the NEPOOL Planning Process Subcommittee, which established numerous NEPOOL policies for transmission and generator owners
- Served as Vice-Chair of the NEPOOL Reliability Committee

1984-1989

## *Meter Engineer*

Commonwealth Electric Company, Plymouth, MA

- Designed and supervised installation of 15 generator metering and data recorders
- Developed customer load plotting and analysis software
- Developed meter equipment order data processing system for four remote offices
- Implemented PC control of meter test boards, which significantly reduced processing and record keeping time
- Managed programming of all electronic meter registers to insure accurate data registration

1979-1984

## *Computer Application Engineer*

Commonwealth Electric Company, Wareham, MA

- Implemented numerous technical and analytical software applications for engineering analysis
- Served as member of decision team for implementation of a new SCADA system

1978-1979

## *San Diego Gas & Electric, Planning Engineer*

San Diego Gas & Electric Company, San Diego, CA

- Performed extensive stability analysis for a new 230 kV transmission interconnection with Mexico
- Performed transmission design and performance analysis for a new 250 mile 500 kV line from San Diego to Arizona

1973-1978

## *New England Gas & Electric Association, Planning Engineer*

New England Gas & Electric Association, Cambridge, MA

- Performed extensive stability analysis for a new 560 MW generating plant on Cape Cod
- Developed transmission plan for a new 345 kV transmission line on Cape Cod
- Developed plans for design and sighting of new 115 / 23 kV substations on Cape Cod

## **EXHIBIT ATTACHMENT CPS-B**

## CAIDI Performance Worse Than Benchmark Mean

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
03	Adams	ADA 801	118		
		ADA 8012	150	125	
		ADA 8015		479	160
		ADA 8016		121	
		ADA 802		344	213
		ADA 8024	232		187
	Aldene Sub	ALD 8016		103	
		ALD 8022			110
		ALD 8024		251	
		ALD 8025			121
		ALD 8026		143	102
	Bayway	BAY 4002	429		
	Bennetts Lane	BEN 8012			207
		BEN 8014	116		
		BEN 8015	169	129	
		BEN 8021		118	
		BEN 8022	105		
		BEN 8023	163		
		BEN 8024		130	
		BEN 8025			143
	Brunswick Sub	BRU 8011		171	
	Carteret	CAT 4009			165
	Clark	CLA 4003			434
		CLA 4007			404
	Cliff Road	CLI 8001			108
	Cranford	CRA 4003		271	
		CRA 4005		236	
		CRA 4007		186	
		CRA 4008		142	
		CRA 4009	106		
		CRA 4011	103		
		CRA 4012		200	
		CRA 4013		372	
		CRA 4014		143	
		CRA 4016			319
	Dayton 8001 Unit	DAY 8002	151		
	Doremus Place	DOR 8032	143		
		DOR 8033	125	115	
		DOR 8042		308	
		DOR 8044	111	196	
	Edison	EDI 4009		106	
	Elizabeth	ELI 4008			173
	Fanwood	FAW 801			510
		FAW 802		131	333
	Finderne	FIN 4003		112	
	First Street	FIR 4001		176	
		FIR 4002		286	181
		FIR 4003		286	
		FIR 4004	104	255	

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
		FIR 4005		286	159
		FIR 4006		255	
		FIR 4007		213	
		FIR 4008		213	
		FIR 4010		213	
		FIR 4011		213	
	Front Street	FRO 4003	266	327	
	Green Brook	GBK 8023	258	114	
	Hancock Street	HAN 400	179		
		HAN 4005		158	
	Harts Lane	HAT 8012	131		
		HAT 8013	120		
		HAT 8014	112	105	
		HAT 8015	111		
		HAT 8021		159	
		HAT 8022		325	112
		HAT 8027		117	
		HAT 8037		234	
	Henry Street	HEN 4009	298		
	Hillside	HIL 4007	160		
	Jersey Avenue	JER 4001	119		
	Keasbey	KEA 4003	125		
		KEA 4004		196	
	Kenilworth	KEN 4001		118	
		KEN 4002		118	
		KEN 4003		118	
		KEN 4004		118	
		KEN 4005		208	118
		KEN 4006	111		118
	Kilmer	KIL 8014	134		
		KIL 8022		158	
		KIL 8023	115	112	
		KIL 8025		105	
		KIL 8034		173	
	Lafayette Road	LAF 8014	108	228	
		LAF 8015		178	157
		LAF 8024		146	
		LAF 8026		107	
	Lake Nelson	LAK 8012		173	
		LAK 8014		163	293
		LAK 8024		131	
	Lehigh Avenue	LEH 4004		120	
		LEH 4006			151
		LEH 4009		483	
	Meadow Road	MEA 801		143	
		MEA 802		153	140
	Mechanic Street	MEC 400	243		124
		MEC 4003			124
		MEC 4004			124

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
Division	Substation	MEC 4005		124	
		MEC 4006		124	
		MEC 4007		303	
		MEC 4008	350	124	
		MEC 4009		124	
		MEC 401		124	
		MEC 4010		124	
		MEC 4012		124	
		MEC 4013		122	
		MEC 8004		210	
Minue Street	Minue Street	MIN 8012		116	
		MIN 8015		102	
		MIN 8024		198	
	Mountain Avenue	MON 800		136	
	New Dover	NED 8012	125	115	
		NED 8016		180	
		NED 8023	233	132	
		NED 8025		240	
		NED 8026	138	122	
North Avenue	North Avenue	NOT 8011	295		
		NOT 8012	105		
		NOT 8024	593		
	North Bridge Street	NBS 8012		165	
		NBS 8013	164		
	Pierson Avenue	PIE 8012		128	
		PIE 8015		115	
		PIE 8021	173		
		PIE 8022		120	
Plainfield	Plainfield	PLA 4007	107	174	
		PLA 4012	104		
		PLA 4013		109	
	Pleasant Street	PLS 4001	342		
	Polhemus Lane	POH 8013	125	120	
		POH 8015	137	498	
		POH 8023		125	
	Rahway	RAH 4001	103		
		RAH 4003	103		
		RAH 4004	104	246	
		RAH 4005	104		
		RAH 4006	104		
		RAH 4007	104		
		RAH 4008	103		
		RAH 4009	104		
		RAH 4010	103	106	
		RAH 4012	114		
Roselle	Roselle	RSL 4008	173		
	Sand Hills	SDH 8021	230	166	
		SDH 8023	140	166	
		SDH 8025	116	113	120
		SDH 8026	191		

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
		SDH 8033		168	
		SDH 8034			249
		SDH 8035	121	125	
	Somerville	SMV 802	161		
		SMV 8023		111	
		SMV 8025	121		
	South Second Street	SOS 8025	113		
	Springfield Road	SPF 8012	136	126	
		SPF 8013			138
		SPF 8014	299		
		SPF 8016		111	
		SPF 8023	104		
		SPF 8024	166	109	
		SPF 8025		182	161
		SPF 8026	111		
	Sunnymeade	SUN 8011		227	
		SUN 8012		103	
		SUN 8013	137	115	
		SUN 8014		127	
		SUN 8018	182		
		SUN 8021		110	
		SUN 8023		132	
		SUN 8024	162	112	
		SUN 8025	108	109	
		SUN 8034			172
		SUN 8045	106		
		SUN 8048	127		
	Tremley	TRE 4002	123		
	Union	UN 4010		113	
		UN 4011		165	
	Vauxhall Road	VXL 4001		106	
	Warinanco	WAN 801	543	106	157
		WAN 802		130	
	Westfield	WFL 8011		125	
		WFL 8012		104	155
		WFL 8023		106	
		WFL 8032		129	
	Woodbridge	WOR 801	123	105	163
		WOR 802	148	159	182
		WOR 803	113	122	123
05	Academy Street	ACA 4005		141	
		ACA 4006		165	
		ACA 4008		188	
	Arcola	ARC 4003	117		
	Bayonne Sub	BAO 8003		118	
		BAO 8013	118		
		BAO 8014		167	443
		BAO 8015		235	
		BAO 8025		107	

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
		BAO 8044		105	107
	Bergen Point	BER 4013	215		
		BER 4015		148	
	Bergenfield	BEF 8001		121	
	Culver Avenue	CUL 4001		156	
		CUL 4004		131	
	Dumont	DUM 400	406		
	East Rutherford Sub	EAT 8011	106		
		EAT 8022		276	
	Englewood	ENG 4004		267	
		ENG 4005		311	132
		ENG 4006		176	
		ENG 4007	140		
		ENG 4009	155		
		ENG 4013		247	
		ENG 4014		127	
	Fairview	FAV 4003	134		
		FAV 4005	102		
	Garfield Avenue	GAE 4001		164	
		GAE 4006	153	118	
	Garfield Place	GAF 4001		170	
		GAF 4004	155		
		GAF 4009		124	
	Greenville	GRN 4008	276		
	Hackensack	HAC 4005	140		
		HAC 4006	103		
		HAC 4007		150	150
		HAC 4009	115		
		HAC 4010	115		
		HAC 4011	115		
		HAC 4012	122		
		HAC 4013	122	184	
		HAC 4016	122		
		HAC 4018	204		
	Harrison	HAR 4001		111	
		HAR 4002		111	
		HAR 4003		111	116
		HAR 4004		111	
		HAR 4005		111	
		HAR 4006	109	111	
		HAR 4007		111	
		HAR 4011		111	
		HAR 4012		111	
		HAR 4013		118	
		HAR 4015		111	
		HAR 4018		111	
		HAR 4019		111	
		HAR 4020		111	
		HAR 4021		111	
		HAR 4022		111	

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
	Hasbrouck Heights	HBH 8004	105		
	Hillsdale	HID 8011	174		
		HID 8012	137		
		HID 8013	131		
		HID 8014	155		
		HID 8021	135		
		HID 8022	102		
		HID 8023	119		
		HID 8025	112	199	
		HID 8041	137		
		HID 8042	117	250	119
	Hoboken	HOE 8011	105		
		HOE 8025	156		
	Homestead	HOM 800	107	267	
		HOM 801	191		
		HOM 803	104		
	Howell Street	HOW 400	103		
	Hudson Terrace	HUD 400	130		
		HUD 4002	105		
		HUD 4004	139		
		HUD 4006	126		
	Jersey City Switch	JCY 8012	103		
		JCY 8013	103		
		JCY 8021	103		
		JCY 8023	103		
		JCY 8031	103		
		JCY 8033	103		
	Kingsland	KIN 8011	122	727	
		KIN 8012	142		
		KIN 8022	107		
	Leonia	LEO 8002	120		
		LEO 8003	129		
		LEO 8010	118		
		LEO 8033	245		
		LEO 8035	280	126	116
		LEO 8041	257		122
		LEO 8042	103		
		LEO 8045	113		
	Little Ferry	LIL 4002	584	141	
	Marshall Street	MAS 4009	149		
		MAS 401	233		
		MAS 4010	225		
	Maywood	MAY 801	112	121	
		MAY 802	345		
		MAY 803	140		
		MAY 804	136	220	109
	New Milford	NEW 801	115	204	310
		NEW 802	136	108	
		NEW 803	195	225	208

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
		NEW 804		162	
	North Bergen	NRB 8013		143	
	Paramus	PAR 4002	256	321	
		PAR 4007		104	
	Penhorn	PEH 8007		120	
	Polk Street	POL 4012		106	
	Ridgefield	RFL 8013		103	176
		RFL 8025	102		103
		RFL 8032		170	
		RFL 8033	125		103
		RFL 8034		178	112
		RFL 8043			132
		RFL 8044	274		
		RFL 8045	109		
	Ridgewood	RGW 400	151	167	1305
		RGW 401		160	1208
	River Edge	RID 4006		112	
		RIG 8003	110	139	122
	River Road Sub	RVR 8011		128	
	Saddle Brook	SAD 8002		147	
		SAD 8007			117
		SAD 8008	125		
		SAD 8033	213		
		SAD 8042	106		
	South Waterfront	SWT 8001		371	
	Spring Valley Rd	SPR 4005			156
		SPR 4006	166		
		SPR 4007		134	
	St Pauls	STP 8001		174	
	Teaneck	TEA 4006		173	
	Third Street	THR 4009		135	
	Tonnelle Avenue	TON 4006		119	
		TON 4007		108	
	Turnpike	TUR 8003		128	
		TUR 8004	122		
		TUR 8015		128	
		TUR 8025	148		
	Union City	UNC 4006	195		
		UNC 4010		103	
	Van Winkle Street	VNL 8004	146	139	
	Waldwick	WAD 801	140	203	
		WAD 802		604	154
	Westwood	WOD 400	375	171	103
07	Allwood	ALL 4006	252		
	Belleville	BEE 4008		130	
	Bloomfield	BLO 4008	154	201	
		BLO 4010		425	
		BLO 4012	150		
		BLO 4013		425	

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
		BLO 4014		191	
		BLO 4016		158	
		BLO 4017		179	
		BLO 4018		208	
	Cedar Grove	CED 8011		103	
		CED 8012			114
		CED 8015		105	120
		CED 8016		233	
		CED 8021		134	107
		CED 8022			106
		CED 8024		111	
	Central Ave	CET 4001		199	389
		CET 4004		125	105
		CET 4008			125
		CET 4012		142	170
		CET 4017			301
	Clay St	CLE 4015		180	
		CLE 4017		277	
	Clifton	CLF 8016		148	
		CLF 8024			275
		CLF 8025			344
	Cook Rd	COR 8011		105	
		COR 8013			112
		COR 8024			161
		COR 8025		124	
		COR 8031			121
		COR 8034			160
	East Orange Sub	EAO 4003		153	
		EAO 4006			144
		EAO 4008		147	
		EAO 4012		193	134
		EAO 4013		103	108
		EAO 4019		165	106
		EAO 4023			113
	Fairlawn	FAR 4001		162	
		FAR 4002		142	
		FAR 4005			174
		FAR 4006		113	234
		FAR 4008			167
		FAR 4009		157	164
	Federal Square	FED 4018		215	
		FED 4019			132
		FED 4030			835
	Foundry St	FOU 8012		106	
		FOU 8022			190
		FOU 8023			105
	Getty Ave	GET 4003		137	
		GET 4004			109
	Great Notch	GRE 4001		177	
		GRE 4002		540	113

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
		GRE 4004		174	
	Haledon	HAL 4004		136	
		HAL 4008		143	
	Hawthorne	HAW 802		113	
	Hinchmans	HNC 8012		110	
		HNC 8014		187	
		HNC 8015		236	253
		HNC 8022		109	
		HNC 8023		126	
		HNC 8024			119
		HNC 8025		150	
	Ironbound	IRO 4006		117	
		IRO 4014		113	510
	Irvington	IRV 4002		148	110
		IRV 4010			170
		IRV 4019			125
		IRV 4020			691
	Jackson Rd	JAC 8012		126	
		JAC 8022			178
		JAC 8023		121	
		JAC 8032			117
		JAC 8043			133
	Kuller Road	KUL 8011		135	
	Lakeside	LAS 4010		288	179
		LAS 4019		215	217
					194
	Laurel Ave	LAU 8014		120	
		LAU 8021		206	
		LAU 8022			223
		LAU 8023		118	103
		LAU 8024			122
		LAU 8025		186	145
		LAU 8034			118
		LAU 8035		106	
		LAU 8036			112
		LAU 8046		142	157
	Legion Place	LEG 4003		128	
	Marion Drive	MAI 8014			157
		MAI 8021			126
		MAI 8023		150	145
		MAI 8024		189	178
	McLean Blvd	MCL 400		178	
		MCL 4004		109	
	Montclair	MNT 400		604	432
		MNT 401		134	206
				213	391
	Nevins Road	NEV 8001			180
		NEV 8002		125	
	Nineteenth Ave	NIN 4001			451
		NIN 4003			148
		NIN 4006		158	163

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
	Nineteenth Ave Unit	NIT 8007		123	125
Norfolk St		NOF 4004	177	145	
		NOF 4008	255		
		NOF 4010	135	217	
		NOF 4016		242	
		NOF 4019	125		
North Paterson		NRP 4003		131	
		NRP 4007		140	
		NRP 4010		102	
		NRP 4013	142		
		NRP 4015	239		
Nutley		NUT 4001	105	533	147
		NUT 4002		437	191
		NUT 4003	568	191	
		NUT 4004		191	
		NUT 4006	568	175	
Oak St		OAK 4006		110	
		OAK 4007	174		
Orange Valley		ORA 4002	247	176	
		ORA 4004		164	
		ORA 4005	142		
		ORA 4007	103	172	
Passaic		PAS 4001	151	119	
		PAS 4002	151	119	
		PAS 4003	151		
		PAS 4004	151	120	
		PAS 4005	151	117	
		PAS 4006	151	120	
		PAS 4007	131	119	
		PAS 4008	151	119	
		PAS 4009	151	119	
		PAS 4010	151	119	
		PAS 4011		117	
		PAS 4012	151	119	
		PAS 4013	151	119	
		PAS 4014	151	119	
		PAS 4015	151	119	
		PAS 4016	151		
		PAS 4017	151	119	
		PAS 4018	151	119	
		PAS 4019	151	119	
		PAS 4020	123	119	
Plank Rd		PLN 4007	128		
		PLN 4010	117		
		PLN 4016	142	192	
Plauderville		PLR 4003		105	
		PLR 4004		242	
Port St		POR 4002	165	159	
		POR 4003		161	214
		POR 4004	125	145	

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
		POR 4006		150	
	So Orange	SOO 4002	144	207	109
		SOO 4003	136	139	
		SOO 4007		155	
		SOO 4010			203
		SOO 4013		201	
		SOO 4014	150		
	So Paterson	SOP 4004		135	
		SOP 4007		743	
		SOP 4010		187	
	Toney's Brook	TNY 4001	108		113
		TNY 4002		110	
		TNY 4003		135	168
		TNY 4004		205	
		TNY 4010	104	145	183
	Totowa	TOT 4001		391	
		TOT 4003		168	
		TOT 4007		199	
	Van Houten Ave	VNH 4002		116	
		VNH 4004		172	
		VNH 4006		128	
		VNH 4008		130	
	Warren Point	WAR 400		211	
	Waverly	WAV 400		347	
		WAV 401	155	238	165
	West Caldwell	WEW 801	118	104	
		WEW 802	238	139	154
		WEW 803		124	
		WEW 804		282	121
	West Orange Sub	WOA 400	192	132	141
		WOA 401	147	148	187
08	Audubon	AUD 4002		222	
		AUD 4005		315	
	Beaver Brook	BEA 8002	103		
		BEA 8003	168		
		BEA 8006	189		
		BEA 8007	108		
		BEA 8008	131		
		BEA 8009	301		
	Bordentown	BOR 4006	152	768	
		BOR 4007		138	
	Bustleton	BUS 8011		113	
		BUS 8012		114	
		BUS 8014		165	
		BUS 8024		109	
		BUS 8025	163	154	
	Chauncey Street	CHA 4012		462	
	Cherry Hill	CHE 4001	142		
		CHE 4004		216	

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
		CHE 4008		124	
	Chester	CHS 4006		109	
		CHS 4008		339	
	Cinnaminson	CIN 8003		165	
		CIN 8010	105		
		CIN 8011		128	
	Clarksville	CLK 8012		103	
		CLK 8013	110		
		CLK 8016		105	
		CLK 8025	122		
	Collingswood	COL 4003		107	
		COL 4004	902		121
	Coxs Corner	CXC 8021		104	
		CXC 8022		127	
	Crosswicks	CRX 8001		165	
		CRX 8002	142		
		CRX 8006	160		
	Cuthbert Blvd	CUT 8002	258	105	
		CUT 8006		119	
		CUT 8007	119	144	
		CUT 8008		159	
		CUT 8010		109	
		CUT 8033		123	
		CUT 8034	128		
		CUT 8035		169	
		CUT 8041		109	
		CUT 8042	127	109	
	Delair	DEA 4008		256	
	Deptford	DFD 8005		158	271
		DFD 8006	149	104	
		DFD 8008		129	111
	Devils Brook	DVB 8011	202	212	
		DVB 8023		111	118
		DVB 8024			205
	East Riverton	EAR 4001		149	
		ERT 8003			161
	Ewing	EWI 4004	832		
		EWI 4006		145	
		EWI 4007		201	
		EWI 4008		176	
	Fernwood	FEN 8041	106	104	
		FER 4005	124		
	Hamilton	HAM 400		145	308
	Hilltop	HLT 8002	115	165	
		HLT 8003	131		
	Kuser Rd	KUS 8001		131	
		KUS 8004	123		
		KUS 8005		213	127
		KUS 8006		105	

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
Division	Substation	KUS 8033		113	
		KUS 8041		155	
		KUS 8043		123	278
		KUS 8044	115		551
		KUS 8045		115	
Division	Lamberton Rd	LAM 800		129	
	Lawnside	LAW 801	108	117	146
		LAW 802	127	163	153
Division	Lawrence Sub	LAW 803	261	109	
		LCE 8004		223	
		LCE 8009		154	
		LCE 8010		115	
		LCE 8033	172		
		LCE 8034			127
		LCE 8035			115
		LCE 8036	126		
Division	Levittown	LCE 8042		102	
		LEV 8001		118	
		LEV 8003	107		163
		LEV 8005		128	144
		LEV 8006			171
		LEV 8007			105
		LEV 8009		139	
		LEV 8010	102		
		LEV 8011			143
		LEV 8012	114		
		LEV 8013			128
		LEV 8014	102	183	
		LEV 8015		132	305
		LIB 4005		137	
Division	Liberty Street	LIB 4009		106	131
		LOC 8004		164	
Division	Lumberton	LUM 801	233	104	
		LUM 802		102	141
Division	Maple Shade	MAD 801	157	172	104
		MAD 802		154	141
		MAD 803	104	150	125
Division	Market Street	MAK 400		144	
		MAR 800	301	123	142
Division	Marlton	MAR 801	330	222	187
		MAR 802	109	226	145
		MDF 8013	127		153
Division	Medford	MDF 802	140	107	
		MDF 8022	113		137
		MDF 8023	160		
		MDF 8024		211	162
		MOY 400		109	123
Division	Mount Laurel	MTL 8011	127	130	167
		MTL 8013			135

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
Mount Rose	Mount Rose	MTL 8014		145	
		MTL 8015			150
		MTL 8021		120	
		MTL 8023			142
		MTL 8025	104		
Penns Neck	Penns Neck	MRO 801	267	198	
		MRO 802	127		124
		PEK 8011	170	123	128
Pine Street	Pine Street	PEK 8021		144	
		PEK 8026	110	118	158
		PIN 4001		476	
Plainsboro	Plainsboro	PIN 4004	254		149
		PIN 4007		191	231
Princeton	Princeton	PLI 8009	142		
		PLI 8012	162		
Rocky Hill	Rocky Hill	PRI 4001	107		157
		ROC 8001		106	
Runnemede	Runnemede	ROC 8002	212		
		RUN 8001		168	
		RUN 8003	140		
Southampton	Southampton	RUN 8004		116	
		SOH 8021	115	134	
		SOH 8022	149	115	
Stanwick	Stanwick	SOH 8032	131	109	127
		STN 4002	322		
Stanwick Unit	Stanwick Unit	STK 8003		111	
		STA 8051	171		
State Street	State Street	STS 4010	106		
		THY 4001	140		
Thirty Second Street	Thirty Second Street	THY 4002	140		
		THY 4003	140		
		THY 4004		103	
		THY 4005	140		
		THY 4006	119		627
		THY 4008	172	323	
		THY 4009	140		
		THY 4011	189		223
		THY 4012		112	
		THY 4013	140		
Thorofare	Thorofare	THO 8011		144	167
		THO 8012		113	
		THO 8013	107	123	135
		THO 8014		145	198
		THO 8021	110	109	162
		THO 8022		137	198
		THO 8024		132	129
Westmont	Westmont	WMT 400		237	148
		WRY 400	114		106
Woodbury	Woodbury	WRY 401	175		103

High CAIDI			Year		
Division	Substation	Circuit	2006	2007	2008
	Woodbury Unit Sub	WBY 804		137	
	Woodlynne	WYN 400		372	179
	Yardville	YRD 8011	236		
		YRD 8012		108	
Total			324	321	297

## **EXHIBIT ATTACHMENT CPS-C**

## SAIFI Performance Worse Than Benchmark Mean

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
03	Adams	ADA 8012			1.208
		ADA 8022		1.474	2.023
		ADA 8023	1.397		1.426
		ADA 8024		1.215	
		ADA 8026	1.401		
	Aldene Sub	ALD 8012	2.77		
		ALD 8014	1.54		
		ALD 8023		1.452	
		ALD 8025	1.262	2.082	
	Avenel	AVE 4007		3.014	
Bennetts Lane	Bayway	BAY 4006	1.958		
	Bennetts Lane	BEN 8012		1.188	
		BEN 8013	1.717	1.352	2.184
		BEN 8016			1.204
		BEN 8023		2.006	1.753
		BEN 8024			1.641
	Brunswick Sub	BEN 8025	1.169		
		BEN 8026		2.305	
	Cliff Road	BRU 8012			1.865
		BRU 8021		2.018	
		BRU 8022		1.734	
Cranford	Cliff Road	CLI 8001		2.097	
	Cranford	CRA 4012		1.157	
		CRA 4013		1.772	
		CRA 4014	2		
	Dayton Unit	CRA 4016	2.517	3.088	
		DAY 8002		1.422	
	Doremus Place	DOR 8012		1.225	
		DOR 8015	1.672		
		DOR 8022	1.393	2.668	
		DOR 8025		1.759	
		DOR 8032		1.799	
		DOR 8034		1.281	
		DOR 8035	2.602		
		DOR 8043	1.798	2.101	
		DOR 8045		2.018	
Edison	Edison	EDI 4006			3.87
	Fanwood	EDI 4009		2.01	
		FAW 801	5.652	3.897	1.263
	Finderne	FAW 802	2.361	2.561	2.667
		FIN 4003	1.706	1.992	
	First Street	FIR 4001		1.969	3.136
		FIR 4002			2.034
		FIR 4005			2.08
		FIR 4006	4.961		
Franklin Unit 2	Franklin Unit 2	FRA 8002	3.971		
	Franklin Unit 3	FRA 8003		2.068	

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
	Front Street	FRO 4008	1.954		
		FRT 8004		1.96	
	Green Brook	GBK 8011	1.508	1.474	
		GBK 8012		1.163	
		GBK 8013	1.585		
		GBK 8014	1.387		
		GBK 8021	1.225	1.874	
		GBK 8022	2.319		
		GBK 8024	2.053		
	Harts Lane	HAT 8012	2.773		
		HAT 8014	1.768		
		HAT 8022	1.515	1.263	
		HAT 8023	1.587		
		HAT 8027	1.779	3.02	
		HAT 8035	1.409	1.968	
		HAT 8037	1.202		
	Keasbey	KEA 4001	1.915		
	Kilmer	KIL 8012	1.852		
		KIL 8013	3.27		
		KIL 8022	1.991		
		KIL 8025		1.391	
		KIL 8034	1.207		
		KIL 8035	1.311	3.651	1.609
		KIL 8042	1.335	1.204	
		KIL 8043	1.678	1.301	1.967
		KIL 8044	1.638		
	Lafayette Road	LAF 8012	1.872	1.95	
		LAF 8022	1.68		
		LAF 8023	1.255	2.101	
	Lake Nelson	LAK 8012		1.194	
		LAK 8024	1.172	2.163	
	Lehigh Avenue	LEH 4002	1.406	2.995	
		LEH 4004	2.008		
	Meadow Road	MEA 801	1.489	2.048	
		MEA 802	1.521	2.725	1.577
	Mechanic Street	MEC 4007		2.045	
		MEC 4013	1.419		
	Minue Street	MIN 8011	1.413		
		MIN 8015	2.669		
		MIN 8023	1.39	1.685	
		MIN 8025	1.711		
	Mountain Avenue	MON 800	1.571	2.695	3.299
	Moutainside Unit	MSD 800	2.136	1.718	
	New Dover	NED 8013	1.175	1.453	
		NED 8014		1.239	1.908
		NED 8015	1.61		
		NED 8026	1.379		
	North Avenue	NOT 8024	1.591		
	North Bridge Street	NBS 8011		1.396	

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
Division	Substation	NBS 8012		1.413	
		NBS 8013		1.858	
		NBS 8021		2.05	
		PIE 8011	2.367		
Division	Substation	PIE 8012	1.164		
		PIE 8013	1.64		
		PIE 8015	2.236		
		PIE 8021	1.299		
		PIE 8022	2.385	2.618	
		PIE 8023	2.135		
		PIE 8024	1.341	2.105	
		PIE 8025	3.463	1.724	
		PLA 4008	1.99		
Division	Substation	PLA 4012	2.013		
		PLA 4013	2.275		
		PLS 4008	1.972		
Division	Substation	POH 8011	2.103	2.124	
		POH 8012		1.206	
		POH 8013		1.563	
		POH 8015		2.018	
		POH 8023	1.509	1.752	
		POH 8024		2.215	
		POH 8025		1.35	
Division	Substation	RAH 4001	2		
		RAH 4002	2.091		
		RAH 4003	1.99		
		RAH 4004	2.182		
		RAH 4005	1.977		
		RAH 4006	1.995		
		RAH 4007	1.999		
		RAH 4008	2.002		
		RAH 4009	2		
		RAH 4010	2.003	2	
		RAH 4011	2.972		
		RAH 4012	2.074	1.207	
Division	Substation	RAR 4002		2.056	
		RAV 8003		1.243	
Division	Substation	RSL 4007	2.007		
		SDH 8024	1.357	1.175	
Division	Substation	SDH 8026		1.52	
		SDH 8031		1.767	
		SDH 8032		1.36	
		SCO 4001	1.612		
Division	Substation	SCO 4003		1.472	
		SMV 8012		1.676	1.64
Division	Substation	SMV 8015	1.276	1.776	
		SMV 802		2.231	
		SMV 8023	1.502		
		SMV 8024		1.684	
		SOS 8025	1.782	1.949	1.516

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
Division	Springfield Road	SPF 8012		3.331	
		SPF 8022		2.521	1.347
		SPF 8023	1.239		
		SPF 8025	1.7		
		SPF 8026	2.495		
	Sunnymeade	SUN 8011	1.556		
		SUN 8012	2.95		
		SUN 8013	1.163	1.256	
		SUN 8015		2.576	
		SUN 8021	2.961		
	Tremley	SUN 8022	2.076		
		SUN 8025	1.192	1.368	
		SUN 8044	1.427	1.163	
		SUN 8045	1.928	1.824	
		SUN 8047	1.866		
		SUN 8049	1.776		
	Union	TRE 4002	1.909		
		UN 4001		2.015	
		UN 4004			1.983
	Vauxhall Road	UN 4010	1.203		
		VXL 4001	1.367	2.052	
		WAN 801		1.753	1.512
	Westfield	WAN 802			2.361
		WFL 8002	1.961		
		WFL 8003	1.267		
		WFL 8032		1.398	
		WFL 8043	2.993	3.138	
	Woodbridge	WOR 801		1.381	
		WOR 803	1.155		
05	Academy Street	ACA 4005	2.007		
		BAO 8006	3.898	2.035	
		BAO 8013		2.573	
		BAO 8015	1.254	1.41	1.77
		BAO 8025	1.706	1.195	
	Bergen Point	BER 4013		1.187	
		BEF 8001		1.355	
	Bergenfield	CAR 8001	1.159	1.309	1.263
		CON 8001	1.835		2.038
	Constable Hook	CUL 4001		2.345	
		CUL 4004		2.062	
		CUL 4007		1.435	
	Culver Avenue	DUM 400	1.232	1.302	2.052
		EAT 8011	1.402		
	Dumont	EAT 8021		1.158	
		EAT 8022	2.832		
		EAT 8023	2.977		
		EAT 8025	1.948		
		ENG 4005		1.196	
	Englewood	ENG 4012	1.926		

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
Division	Substation	ENG 4013	4.186	3.056	
		ENG 4014	2.118		
		ENL 8004	1.725	1.555	
		FAV 4002	1.402		
Fairview		FAV 4006	1.992		
		FAV 4008	1.963	2.871	
		FOT 8004		1.927	
Garfield Avenue		GAE 4006	2.917	2.969	
		GAF 4004	2.155		
		GRN 4006		2	
Greenville		HAC 4007	1.98		
		HAC 4018	1.947		
Hackensack		HAR 4003		1.562	
		HAR 4013	3.103		
		HAR 4014	1.965	2.011	
		HAR 4020	2.927		
Harrison		HBG 4001		2.037	
		HBG 4002		2.325	
		HBG 4003		2.121	
		HBG 4004		2.071	
		HBG 4006		3.189	
		HBG 4007		2.034	
		HBG 4008	1.683	4.032	
		HBG 4009		2.005	
		HBG 4010		3	
		HBG 4011		2.125	
Hasbrouck Heights		HBH 8004	2.121		
		HID 8011		2.1	
		HID 8012		2.115	
		HID 8014		1.548	
		HID 8021	1.174	1.298	1.292
		HID 8022	1.452		
		HID 8023		3.827	
		HID 8025		4.081	
		HID 8033	2.007	3.695	
		HID 8042		1.973	
Hillsdale		HID 8043	2.19		
		HOM 802	2.499		
		HOM 803		2.008	
		KIN 8021		1.456	
Homestead		LEO 8003		2.898	
		LEO 8005	1.479	3.121	
		LEO 8007		3.796	
		LEO 8031	1.744	1.865	2.341
		LEO 8032		1.634	
		LEO 8033	1.257	2.489	
		LEO 8034		3.131	
		LEO 8035		1.286	
		LEO 8041		2.796	
		LEO 8042		1.608	

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
		LEO 8043			1.574
		LEO 8044		1.67	
		LEO 8045	1.657		
Little Ferry	LIT 8004		1.179		
Lodi	LOI 8001		1.513		
Lyndhurst	LYN 8001		1.795	2.24	
Madison Street	MDS 4002		1.719		
Marshall Street	MAS 4004		1.921	2.01	
	MAS 4010			1.333	
Maywood	MAY 801	1.515	1.919		
	MAY 802	2.135	2.431		
	MAY 803	1.536	1.227	2.45	
New Milford	NEW 801	3.258	3.754	2.375	
	NEW 802	1.647	2.941	3.772	
	NEW 803	2.672	3.293	1.657	
	NEW 804	2.291	4.617	2.985	
North Bergen	NRB 8012			1.981	
Paramus	PAR 4006	1.213			
Penhorn	PEH 8001	1.584			
	PEH 8008	3.284			
	PEH 8013	1.56			
	PEH 8022		1.342		
	PEH 8025		1.606		
Ridgefield	RFD 4001			3.032	
	RFD 4002			3.143	
	RFD 4003			3.931	
	RFD 4004			4.927	
	RFD 4005			3.098	
	RFD 4006			3.442	
	RFL 8011	1.159			
	RFL 8014	1.284			
	RFL 8015	1.543			
	RFL 8034	1.698			
	RFL 8035		1.678		
	RFL 8042	2.433			
	RFL 8043		2.202		
	RFL 8045		1.213		
Ridgewood	RGW 401		1.965		
River Edge	RID 4001		1.714		
	RID 4003	2.053	1.912		
	RID 4005		1.983	2.715	
	RID 4006		2		
	RIG 8003	1.384		2.488	
River Road Sub	RVR 8021	1.625			
Saddle Brook	SAD 8001	1.155			
	SAD 8006		1.196		
	SAD 8007		1.201		
	SAD 8032		1.316		
	SAD 8033	2.881		2.218	

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
	SAD 8042		1.607		
	SAD 8044		1.639	1.738	
St Pauls	STP 8001			2.351	
Teaneck	TEA 4003	2.422			
	TEA 4005			1.966	
	TEA 4009			2.006	
Turnpike	TUR 8001	3.492			
Van Winkle Street	VNL 8004		1.343		
	VNL 8005		1.275	1.918	
Waldwick	WAD 801	3.596	2.054	2.288	
	WAD 802	3.018	1.304	2.167	
West New York	WNY 400		2.035	2.046	
	WNY 401			2.04	
Westwood	WOD 400	1.294		2.432	
07	Allwood	ALL 4006		2.021	
	Bloomfield	BLO 4016		1.157	
	Cedar Grove	CED 8013	1.484	1.546	
		CED 8022	2.806	1.168	
		CED 8023		3.828	
		CED 8025	2.421		
		CED 8026		1.573	
	Central Ave	CET 4004	2.07	1.364	
		CET 4008		1.562	
		CET 4012		1.975	
Clifton	Clay St	CLE 4001		1.478	
		CLE 4003		1.938	
		CLE 4014	1.942		
		CLE 4015	1.183		
		CLF 8012		1.543	
		CLF 8015		1.611	
		CLF 8016	1.183	1.571	1.704
		CLF 8022		1.86	1.568
		CLF 8024		1.854	
	Cook Rd	COR 8011	1.565	2.106	4.229
		COR 8012		4.733	
		COR 8013		1.976	
		COR 8015	1.328		1.72
		COR 8022	2.227		
		COR 8023		1.776	
		COR 8024		2.36	
		COR 8025		2.056	
		COR 8031	3.116		
		COR 8032	1.656	4.526	2.874
		COR 8033	3.446	1.205	
		COR 8042	1.371	1.575	
		COR 8043	1.805	1.785	
		COR 8044		4.433	
	East Orange Sub	EAO 4001	1.969		
		EAO 4002	1.991		

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
		EAO 4004	1.781		
		EAO 4005	2		
		EAO 4007	2		
		EAO 4010	2.037		
		EAO 4011	2		
		EAO 4012	1.303		
		EAO 4020	2.085		
		EAO 4021	1.674		
		EAO 4022	2.196		
		EAO 4023	2.992		
		EAO 4025	1.998		
	Fairlawn	FAR 4006	1.96		
	Federal Square	FED 4022		2.093	
		FED 4030		1.978	
	Foundry St	FOU 8012		1.316	
		FOU 8013		2.792	
		FOU 8014	2.44	3.279	2.134
		FOU 8022		3.216	1.327
		FOU 8023		3.099	2.879
		FOU 8024		4.108	
	Fourtieth St	FOH 4002	2.999	1.458	
		FOH 4004			3.437
		FOH 4006		1.173	
		FOH 4007		1.362	
	Getty Ave	GET 4002			2.098
		GET 4003			2.008
		GET 4004			2.029
	Haledon	HAL 4002		1.38	1.971
		HAL 4005			3.267
		HAL 4006		1.989	
		HAL 4007			3.086
		HAL 4008		1.47	
	Hawthorne	HAW 801		2.602	2.206
		HAW 802	1.667	1.438	1.356
	Hinchmans	HNC 8012	1.839		1.229
		HNC 8024			2.558
	Ironbound	IRO 4003	1.264		
		IRO 4005		1.561	
	Irvington	IRV 4002		1.385	
		IRV 4004		1.989	
		IRV 4006			2.028
		IRV 4010		2.003	
		IRV 4011		1.159	
		IRV 4015		1.207	
		IRV 4016		2.012	
		IRV 4017		2.002	
		IRV 4019		1.233	
		IRV 4020		1.988	
	Jackson Rd	JAC 8012			1.173
		JAC 8015			1.221

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
JAC		JAC 8022	1.273		
		JAC 8023		1.24	
		JAC 8024	1.628		
		JAC 8025		2.033	
		JAC 8032	3.044	1.699	1.386
		JAC 8033	3.709		4.223
KULLER ROAD	KULLER ROAD	KUL 8012	2.347		2.098
		KUL 8013		1.706	
		KUL 8022		1.227	
		KUL 8023	1.345		
Lakeside	Lakeside	LAS 4010			2.018
		LAS 4019	1.965	3.623	
LAUREL AVE	LAUREL AVE	LAU 8011	1.178		
		LAU 8015	3.273	1.906	1.553
		LAU 8021			1.612
		LAU 8024			1.189
		LAU 8035	2.06	2.38	1.625
		LAU 8036		1.523	1.312
		LAU 8046			2.109
MARION DRIVE	MARION DRIVE	MAI 8011	1.402	4.826	2.144
		MAI 8012	1.896	1.175	2.057
		MAI 8013	5.403	2.219	
		MAI 8014	1.242	2.053	
		MAI 8021	3.129	2.939	
		MAI 8022	1.818		
		MAI 8024	1.805	2.393	
MCLEAN BLVD	MCLEAN BLVD	MCL 400			1.407
		MCL 4006			3.008
		MCL 4009	1.472	2.214	
		MCL 4010	2.004		
Montclair	Montclair	MNT 400	3.263		1.154
		MNT 401	4.021	1.5	
Nevins Road	Nevins Road	NEV 8001	1.615		1.994
		NEV 8002		1.751	2.112
Nineteenth Ave	Nineteenth Ave	NIN 4002			3.03
		NIN 4006			1.274
North Paterson	North Paterson	NRP 4002	1.995		
		NRP 4003			1.288
		NRP 4005			1.231
		NRP 4007			2.055
		NRP 4010			2.064
		NRP 4013	1.946		
		NRP 4015	2.017	3.009	
Nutley	Nutley	NUT 4001			3.092
		NUT 4002		1.378	
Oak St	Oak St	OAK 4003			2.158
		OAK 4006			1.985
		OAK 4008			1.221
Orange Valley	Orange Valley	ORA 4001	1.347	2.082	
		ORA 4004		1.182	

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
		ORA 4006		3.997	2.061
		ORA 4007	1.929		2.504
Passaic		PAS 4001		2.01	
		PAS 4002		1.962	
		PAS 4003		3.454	
		PAS 4004		1.953	
		PAS 4005		2.829	
		PAS 4006		1.944	
		PAS 4007	1.956	1.977	
		PAS 4008		1.982	
		PAS 4009		1.986	
		PAS 4010		1.994	
		PAS 4011	2.033	6.583	2
		PAS 4012		1.991	
		PAS 4013		1.992	
		PAS 4014		1.987	
		PAS 4015		1.991	
		PAS 4016		2.967	
		PAS 4017		1.952	
		PAS 4018		1.99	
		PAS 4019		1.2	
		PAS 4020	1.994	1.981	
Paterson		PAT 4003		2.924	
		PAT 4010		2.042	
		PAT 4011	2.998		
		PAT 4012	2.051		4.039
		PAT 4016	1.318		
Plank Rd		PLN 4005		2	
		PLN 4016	1.377		
Plauderville		PLR 4007		4.945	
Port St		POR 4002	1.958	1.833	
		POR 4003		2	2.103
		POR 4004		4.103	
		POR 4006		4	
So Orange		SOO 4002		1.664	
		SOO 4003		2.263	
		SOO 4004	2.424		
		SOO 4007		2.104	
		SOO 4012	1.689	2.058	
		SOO 4013	2.382		4.148
So Paterson		SOP 4004		2.028	
		SOP 4005		2.066	
		SOP 4010		2.003	
Toneys Brook		TNY 4001	2.003		
		TNY 4002	2.742	1.217	
		TNY 4004	2.059		
Totowa		TOT 4001	2.007		2.375
		TOT 4003		2.063	
		TOT 4007		3	
Van Houten Ave		VNH 4003	2.003		

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
		VNH 4006	4.306		
		VNH 4008		1.58	
	Warren Point	WAR 400	2.933	2.016	1.271
	Waverly	WAV 400		3.892	
		WAV 401	1.274	1.936	1.397
	West Caldwell	WEW 801	1.541	1.577	2.003
		WEW 802			2.335
		WEW 803	1.513		
		WEW 804	2.098	2.81	2.166
08	Audubon	AUD 4002		1.977	
		AUD 4004	1.986		
	Beaver Brook	BEA 8001	1.361	2.557	
		BEA 8002		1.376	
		BEA 8004			1.665
		BEA 8005	1.261	1.641	2.22
		BEA 8006			1.178
		BEA 8007		1.227	
		BEA 8008		1.167	1.471
		BEA 8009		1.663	1.598
	Bordentown	BOR 4007		1.282	2.122
	Bustleton	BUS 8013	1.315	2.791	3.046
		BUS 8014	1.645		2.871
		BUS 8015	1.965		2.612
		BUS 8022		1.179	1.38
		BUS 8023		1.306	1.325
		BUS 8024	1.336	1.978	3.097
	Camden Sub	CAS 8002	1.434		3.402
	Chauncey Street	CHA 4001	3.203		
		CHA 4005		2.036	
		CHA 4009	2.659		
		CHA 4014	3.051		
		CHA 4015	2.613		
	Cinnaminson	CIN 8001	1.273		
		CIN 8002	1.563		
		CIN 8005	2.069		
		CIN 8006	1.629		
		CIN 8009		1.553	
		CIN 8010	1.697		
		CIN 8011	2.61		
		CIN 8012	1.269		
		CIN 8033		1.575	
		CIN 8041		2.222	
	Clarksville	CLK 8011		2.051	
		CLK 8013	1.571		
		CLK 8014	1.849	1.54	1.154
		CLK 8015	2.441		1.581
		CLK 8026		2.844	
	Collingswood	COL 4003	3.872		
	Coxs Corner	CXC 8021		1.184	

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
			CXC 8022	1.377	1.37
Crosswicks	Crosswicks	CRX 8001	3.782	1.586	
		CRX 8002		1.376	
		CRX 8003	2.077		
		CRX 8004		1.302	
		CRX 8006		2.184	
Cuthbert Blvd	Cuthbert Blvd	CUT 8001		1.277	
		CUT 8002		1.645	
		CUT 8004		2.63	2.354
		CUT 8005	1.341	1.191	
		CUT 8010	1.594		
		CUT 8032	2.13	2.774	
		CUT 8033		1.586	
		CUT 8034			3.706
		CUT 8035		2.992	
		CUT 8041	2.128		
Deptford	Deptford	CUT 8042		2.035	
		CUT 8044	2.311		
		DFD 8001		1.932	
		DFD 8002		2.176	1.906
		DFD 8003		3.042	
		DFD 8004	3.187	1.208	1.505
		DFD 8006		1.464	
		DFD 8007	1.432		
		DFD 8008		1.297	
		DFD 8010	2.087	2.819	
Devils Brook	Devils Brook	DVB 8013	2.126		
		DVB 8025			1.916
East Riverton	EAR 4002			1.17	
Ewing	Ewing	EWI 4007		2.954	2.044
		EWI 4008		2	
Fernwood	Fernwood	FEN 8041		1.387	
		FER 4007			2.04
		FER 4008		2	
		HAD 4002		1.315	2.385
Haddon Heights	Haddon Heights	HAD 4003		3.003	2.038
		HAD 4005		2.994	
		HAD 4008		3.114	
		HAD 4009		2.022	2.088
		HAD 4010	3.088	2.018	
Hamilton	HAM 400			2.012	
Hilltop	HLT 8003		1.254		
Kuser Rd	Kuser Rd	KUS 8004	1.58		
		KUS 8005		1.682	
		KUS 8007	2.154	1.484	
		KUS 8008	1.276	2.307	
		KUS 8032	2.29	2.088	
		KUS 8034		1.808	
		KUS 8043		1.794	
		KUS 8044		1.695	

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
Lamberton Rd	LAM 800		1.435		
Lawnside	LAW 801			2.306	1.402
	LAW 802		4.191	1.264	1.395
Lawrence Sub	LCE 8003		2.484	1.874	
	LCE 8004		1.47		
	LCE 8006		1.699	1.769	
	LCE 8008		1.759		
	LCE 8009			1.259	3.011
	LCE 8042		1.503	4.094	
	LCE 8044		1.731		
	LCE 8046		1.973		
Lawrence Unit Sub	LCU 8051		2.123	3.202	2.7
Levittown	LEV 8001			1.299	
	LEV 8003			1.492	
	LEV 8004			2.867	1.925
	LEV 8005		2.307		
	LEV 8006		1.225		
	LEV 8007		1.63		1.176
	LEV 8008			1.578	
	LEV 8010			1.853	
	LEV 8012				1.393
	LEV 8016		1.255	2.407	
	LEV 8018			2.057	
Liberty Street	LIB 4007				1.774
Lumberton	LUM 801				1.648
	LUM 802		3.055		1.731
Maple Shade	MAD 801		2.184	1.383	2.815
	MAD 802			3.035	1.957
	MAD 803			1.648	2.478
Market Street	MAK 400			1.373	
Marlton	MAR 800			1.787	
	MAR 801		1.226	1.491	1.266
	MAR 802			1.165	
Medford	MDF 801			1.863	
	MDF 8013				1.38
	MDF 8022			1.347	1.955
	MDF 8023			1.452	
	MDF 8024		1.915	1.476	2.16
Mount Laurel	MTL 8012		3.666	3.09	1.609
	MTL 8013		1.298	2.692	
	MTL 8021				2.1
	MTL 8023			1.657	
	MTL 8025			1.828	2.326
Mount Rose	MRO 801		3.526	1.694	6.069
	MRO 802		1.297	3.886	2.597
Penns Neck	PEK 8011		1.225		
	PEK 8021		2.563		
	PEK 8022		1.973	4.093	3.95
	PEK 8023		1.691		1.923

High SAIFI			Year		
Division	Substation	Circuit	2006	2007	2008
		PEK 8035	1.723		
	Pine Street	PIN 4004		1.629	
Plainsboro		PLI 8004	1.323	1.291	
		PLI 8005	2.161	1.211	
		PLI 8006	2.191	1.376	
		PLI 8007	2.738	1.66	2.15
		PLI 8011		1.375	
		PLI 8012		1.508	
Princeton		PRI 4001	3.02	1.152	
		PRI 4004		2.967	
Riverside	RIV 8006		1.591		
Rocky Hill		ROC 8001		1.628	1.623
		ROC 8002	3.045	1.919	1.748
Runnemede	RUN 8004		2.825		
Southampton		SOH 8021		4.742	
		SOH 8022		3.089	
		SOH 8031	1.966	1.359	
		SOH 8032	1.17	2.238	
Stanwick Unit	STK 8003			2.65	
State Street	STA 8041		1.486		
Thirty Second Street		THY 4003		1.254	
		THY 4004	2.045	1.339	
		THY 4007	1.967	1.538	
		THY 4010	1.993		
		THY 4011	1.154		
		THY 4012	1.981		
		THY 4013		2.242	
Thorofare		THY 4014	1.987		
		THO 8011		1.206	
		THO 8012		1.337	
		THO 8013	1.903	1.646	2.035
		THO 8021		1.531	2.462
		THO 8023		2.788	
Westmont		THO 8024		1.34	1.788
		WMT 400	2	2.236	
Woodbury		WRY 400	1.992		
		WRY 401	1.993	1.151	
Woodlynne	WYN 400		1.257	1.3	
Yardville		YRD 8012		1.541	
		YRD 8013		1.665	
		YRD 8022	2.043		
Total			303	329	314

## **EXHIBIT ATTACHMENT CPS-D**

## Circuits With >25% Overload

Division	kV	Circuit A	2009	2010	2011
Central	4	CAT 4005	26.6%	120.5%	121.2%
Central	4	CRA 4013	24.4%	37.1%	38.9%
Central	4	FIR 4003	23.6%	25.3%	27.0%
Central	4	MEC 4013	44.1%	44.1%	44.1%
Central	4	SCO 4001	68.3%	68.7%	69.6%
Central	4	SCO 4002	64.3%	65.2%	66.1%
Central	4	SCO 4003	44.1%	44.9%	45.4%
Central	13	ADA 8011	24.3%	27.0%	29.3%
Central	13	ADA 8022	19.4%	23.1%	25.4%
Central	13	ADA 8024	33.9%	38.1%	40.6%
Central	13	ALD 8014	24.6%	26.9%	29.1%
Central	13	ALD 8025	27.1%	28.9%	31.1%
Central	13	BEN 8013	15.6%	24.6%	27.7%
Central	13	GBK 8013	23.0%	25.3%	27.9%
Central	13	GBK 8021	28.4%	30.6%	33.1%
Central	13	LAF 8011	23.3%	25.0%	26.3%
Central	13	LAK 8014	41.7%	57.4%	65.3%
Central	13	MEA 8025	29.6%	7.3%	7.9%
Central	13	PIE 8011	9.4%	30.3%	33.6%
Central	13	SDH 8025	25.3%	28.4%	32.9%
Central	13	SDH 8026	20.4%	23.4%	27.7%
Central	13	SDH 8035	22.6%	25.6%	30.0%
Central	13	SMV 8014	14.7%	36.6%	40.4%
MET	13	BRA 8011	30.6%	23.7%	24.3%
MET	13	CLF 8023	13.9%	25.0%	27.0%
MET	13	CLF 8025	24.1%	27.3%	28.7%
MET	13	FOU 8014	14.6%	24.7%	26.6%
MET	13	HAW 8014	25.3%	34.0%	34.7%
MET	13	KUL 8011	22.3%	24.4%	26.7%
MET	13	MAI 8012	30.0%	31.7%	33.6%
MET	13	WAD 8023	30.0%	30.7%	31.4%
PAL	4	ENG 4004	34.1%	35.4%	36.6%
PAL	4	ENG 4005	25.3%	26.7%	28.1%
PAL	4	ENG 4007	26.2%	27.3%	28.5%
PAL	4	ENG 4009	42.8%	44.1%	45.5%
PAL	4	GAE 4006	9.3%	24.7%	26.0%
PAL	4	HAR 4003		27.4%	28.8%
PAL	4	MOG 4006	8.2%	30.6%	32.3%
PAL	4	TEA 4003	9.0%	30.8%	32.2%
PAL	4	THR 4009	9.3%	32.8%	34.3%
PAL	4	TON 4002	8.0%	48.3%	48.3%
PAL	13	BAO 8022		32.6%	32.9%
PAL	13	CON 8001		29.0%	29.3%
PAL	13	HOM 8023	46.0%		
PAL	13	LEO 8044	35.7%	35.7%	

<b>Division</b>	<b>kV</b>	<b>Circuit A</b>	<b>2009</b>	<b>2010</b>	<b>2011</b>
PAL	13	NRB 8013	41.4%		
SOU	13	BUS 8023	38.0%	42.1%	46.3%
SOU	13	CRX 8002	38.3%	28.3%	32.1%
SOU	13	CRX 8005	27.4%	18.1%	21.7%
SOU	13	CUT 8004	21.9%	25.6%	16.4%
SOU	13	DFD 8001	25.3%	29.1%	19.7%
SOU	13	LUM 8022	36.9%	12.9%	16.1%
SOU	13	MAD 8033	36.0%	26.1%	29.9%
SOU	13	MDF 8011	41.0%	16.1%	19.7%
SOU	13	MTL 8014	34.0%	38.1%	42.3%
SOU	13	PEK 8013	43.6%	18.3%	21.9%
SOU	13	PEK 8021	38.1%	42.3%	31.9%
SOU	13	YRD 8013	34.6%	24.9%	28.6%