LEGEND

01 STORMWATER INLET (QTY. = 113)

OUTFALL STRUCTURE (QTY. = 3)

NOTE:

Inlets #47, 48, and 71 do not have bicycle safe grates per the Public Complex Stormwater General Permit Design Standards. The inlets shall be retrofitted when in direct contact with any repaving, repairing, or resurfacing or when in direct contact with any reconstruction or alterations of facilities. The storm drain retrofits shall meet the Permit's Design Standards for Storm Drain Inlets.

0 80 160
SCALE: 1" = 80'

© Mott MacDonald

This document is issued for the party which commissioned it and for specific purposes connected with the captioned project only. It should not be relied upon by any other party or used for any other purpose.
We accept no responsibility for the consequences of this document being relied upon by any other party, or being used for any other purpose, or containing any error or omission which is due to an error or omission in data supplied to us by other parties.

MOTT MACDONALD

Certificate No. 24GA28016600

111 WOOD AVENUE SOUTH
ISELIN, NJ 08830
UNITED STATES

T + 1 800 832 3272
F + 1 973 376 1072
www.mottmacamericas.com

Client

THE STATE OF NEW JERSEY
DEPARTMENT OF THE TREASURY
DIVISION OF PROPERTY MANAGEMENT
AND CONSTRUCTION

Rev	Date	Drawn	Description	Chk'd	App'd
0	9/9/2019	DWH	FOR CLIENT REVIEW	JJK	BEH

BRIAN E. HENNING
Professional Engineer Lic. NO. 49196

_____ Date _____

Project Number	B/O	Total
507101106	1	1

Designed			Eng check		
Drawn	DWH	9/2019	Coordination		
Dwg check	JJK	9/2019	Approved	BEH	9/2019

Scale at ARCH E1	Status	Rev	Security
As Shown		0	

Drawing Number C-101

Title

HUNTERDON DEVELOPMENTAL CENTER
40 PITTSTOWN ROAD
CLINTON, NEW JERSEY 08809
STORMWATER FACILITIES
INVENTORY MAP